

ADDENDUM NUMBER: Addendum - One

REQUEST for PROPOSAL: Renovation of third floor – Safety Building
Domestic Violence Unit
Milwaukee County District Attorney's Office
821 West State Street
Milwaukee, WI. 53233-1427

PROJECT NUMBER: C070-11421

DATE OF ADDENDUM: March 21, 2011

This Addendum to the Request for Proposal (FRP) is issued to modify, explain or correct the original Documents, Dated March 03, 2011, and is hereby made part of the Request for Proposal. Acknowledge receipt of this addendum in the Letter of Transmittal, as part of your proposal submission.

1). SCOPE OF CONSULTANT SERVICES

B. BASIC DESIGN SERVICES

2. Schematic Design – Add the following paragraph:

The Architect / Engineering consultant as part of his Schematic Design shall investigate, document, and determine if there is enough capacity in the existing air handling unit, A/C-2, to supply the HVAC for the renovated area to become the Domestic Violence Unit. The existing air handling A/C-2 is located in the penthouse mechanical room and has dual duct supply mains located in the light court. These dual duct supply mains serve the Communication Center located on the third floor.

The Architect / Engineering consultant as part of the Schematic Design shall also investigate, document, and determine the available cooling capacity of the existing chiller and chilled water system that supplies A/C-2.

2). SCOPE OF CONSULTANTS SERVICES

E. ADDITIONAL SERVICES

1. Delete this paragraph in its entirety.
2. Delete this paragraph in its entirety.

As stated in the Milwaukee County's, Department of Transportation and Public Works, Type "A" Agreement for Professional Services, Section 3.6 Construction Phase, shall take precedent as the requirements for the successful Architect / Engineer consultant in providing construction observation services.

2). SCOPE OF CONSULTANTS SERVICES

H. PROPOSAL SUBMISSION REQUIREMENTS AND FORMAT

1. Revise paragraph as follows:

The Proposal must be submitted by **Monday; March 28, 2011 at 2:00 P.M.** to:
Milwaukee County Department of Transportation and Public Works
Architectural, Engineering, & Environmental Services
City Campus, second floor
2711 West Wells Street
p. (414) 278-4854
f. (414) 223-1366

END OF SECTION

Addendum One-1